

# GASOLINE

## A92



NO.	PROPERTIES	UNIT	RESULT		TEST METHOD
			MAX	MIN	
1.	Appearance	-	Clear & bright		Visual
2.	Density@15.5°C	Kg/m <sup>3</sup>	760	720	D 1298 &D4052
3.	Reid vapor pressure@37.8°C	PSI	Sum.8 Wint.9	-	ASTM D 323
4.	RON	-	-	92	ASTM D 2699
5.	IBP	°C	-	35	ASTM D 86
6.	10%	°C	70	-	ASTM D 86
7.	50%	°C	120	-	ASTM D 86
8.	90%	°C	190	-	ASTM D 86
9.	FBP	°C	210	-	ASTM D 86
10.	Residue	MI	1.5	-	ASTM D 86
11.	Loss	MI	1.5	-	ASTM D 86
12.	Existent gum	Mg/100ml	4	-	ASTM D 381
13.	Induction period	Min	-	360	ASTM D 525
14.	Total sulphur content	%wt	0.1	-	ASTM D 5453
15.	Copper corrosion strip@50°C	-	1a	-	ASTM D 130
16.	Doctor test	-	Neg	-	ASTM D 4952
17.	Benzene	%Vol	3	-	ASTM D 3606
18.	Aromatic	%Vol	40	-	ASTM D 1319
19.	Oxygenates	%Vol	760	720	ASTM D 4815
20.	Olefins	%Vol	Sum.8 Wint.9	-	Visual

**The analysis will be customizable & produce able as per buyer's request**